


1 2 3 4 5 6 7 8

A
B
C
D
E
F
G
H

A
B
C
D
E
F
G
H



Milano

HEIGHT (MM)	WIDTH (MM)	COLUMNS	PIPE CENTRES (APPROX. MM)	BTU T30	BTU T50	BTU T65	PROJECTION FROM WALL (MM)	WALL TO CENTRE TAPPING (MM)
300	605	3	695	745	1424	1984	124	74
300	785	3	875	975	1862	2594	124	74
300	1010	3	1100	1261	2410	3358	124	74
300	1190	3	1280	1467	2849	3968	124	74
300	1415	3	1505	1778	3391	4725	122	74
300	1595	3	1685	2007	3829	5335	122	74
500	785	3	875	1332	2608	3683	122	74
500	1010	3	1100	1724	3375	4766	122	74
500	1190	3	1280	2038	3989	5632	122	74
500	1415	3	1505	2429	4756	6716	122	74
600	425	3	515	871	1750	2504	124	74
600	605	3	695	1258	2528	3617	124	74
600	785	3	875	1645	3305	4729	124	74
600	1010	3	1100	2129	4277	6120	124	74
600	1190	3	1280	2516	5055	7233	124	74
600	1415	3	1505	2910	5699	8049	122	74
600	1595	3	1685	3286	6435	9088	122	74
750	785	3	875	1992	3863	5428	122	74
750	1010	3	1100	2578	4999	7024	122	74
750	1190	3	1280	3046	5908	8301	122	74
750	1415	3	1505	3632	7044	9897	122	74

1 2 3 4 5 6 7 8