

This certificate is valid for Building Regulations & associated technical guidance in force on the date of registration and for the regulations in the countries indicated

## Niko Distribution Ltd - Doc M Layout Sanitary Ware Pack

### Description of Product

The NIKO DOC M pack comprises the necessary sanitary ware and associated rails needed to ensure that the requirements relating to disabled toilet layout can be accommodated. Installer guidance for positioning is also provided.



### Key Factors Assessed

- Health, Hygiene and Environmental - Approved Document C
- Safety in Use - Approved Document A
- Durability serviceability and identification

### Validity

This certificate was first issued on 22<sup>nd</sup> February 2013 and is valid until 22<sup>nd</sup> February 2018.  
Issue Dated 12<sup>th</sup> March 2015

## Scope of Registration

The assessment relates only to items shown on the above drawings that are supplied in the NIKO DOC M pack. Further fittings are required to enable full compliance with Part M, additional fittings that are required are soap dispenser, paper towel dispenser, alarm reset button, toilet paper dispenser, mirror, disposal bin, shelves, clothes hook and alarm cord.

## Conditions of Certificate

The assessment relates only to items shown on the above drawings that are supplied in the NIKO DOC M pack. Further fittings are required to enable full compliance with Part M, additional fittings that are required are soap dispenser, paper towel dispenser, alarm reset button, toilet paper dispenser, mirror, disposal bin, shelves, clothes hook and alarm cord. The centre push button flushing mechanism needs to be operable with a clenched fist. As such button needs to be raised above the cistern and flushing mechanism completed before button can be depressed below cistern top. Shelving for sanitary disposal eg colostomy bag, must not be sited above the button, see A 01/11/12 – Doc "M" Pack Layout Plan View.

LABC consider that, the NIKO DOC M pack, will meet the functional requirements of the Building Regulations (listed below) if the criteria detailed in this certificate are met;



### The Building Regulations 2010 (as amended) England & Wales

Regulation 7	Materials and workmanship
Note:	The products are acceptable.
AD G	Sanitation, hot water safety & water efficiency
Note:	Subject to limitations detailed below in Conditions section.
AD H	Drainage & Waste Disposal
Note:	Subject to limitations detailed below in Conditions section.
AD M	Access to and use of Buildings
Note:	Further fittings are required to enable full compliance with Part M



### The Building Regulations 2010 (as amended) England

None presently



### The Building Regulations 2010 (as amended) Wales

None presently



### The Building (Scotland) Regulations 2004 (as amended)

If you would like to discuss a specific use of the product in Scotland it will require an additional assessment under the Scottish Building Regulations and accordingly you should contact the LABSS STAS Administrator at [www.labss.org](http://www.labss.org)

## Non-Regulatory Information



### LABC Warranty

This product confirms to the Functional Requirements of the LABC Warranty Technical Manual.

## Supporting Documentation

Ref A 01/11/12 – Doc “M” Pack Layout Wall A View

Ref A 01/11/12 – Doc “M” Pack Layout Plan View

## Contact Information

Niko Distribution Limited

Hamnett House

Gibbett Street

Highroad Well

Halifax

HX2 0AX

Tel: 01422 356863

Email: [Andrew.Robinson@nikoltd.com](mailto:Andrew.Robinson@nikoltd.com)

Web: [www.nikoltd.com](http://www.nikoltd.com)